## CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION OFFICE OF THE STATE FIRE MARSHAL

## FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM





**LISTING No.** 7165-1076:184 Page 1 of 1

**CATEGORY:** Control Unit (Non High-Rise)

LISTEE: Kidde-Fenwal, Inc., 400 Main Street, Ashland, MA 01721

Contact: Terrill Garland (508) 881-2000 FAX (508) 881-1773

**DESIGN**: Model FENWALNET 6000 fire alarm control units. Automatic, manual, local, central

station, waterflow, sprinkler supervisory and releasing device services. Refer to the listee's data sheet for detailed product description and operational considerations. System

components:

74-600000-001 FENWALNET 6000 Control Unit (Blue) 74-600000-510 FENWALNET 6000 Control Unit (Red)

74-600000-004 Motherboard 74-600000-011 Keypad/Display 06-118394-002 Power Supply

06-220023-001 In-Line Releasing Device (EOLD)

74-600000-002 Enclosure (Blue) 74-600000-511 Enclosure (Red)

\*74-600000-009 Network Interface Card

**RATING:** Primary: 120/240 VAC, Standby: 24 VDC

**INSTALLATION:** In accordance with listee's printed installation instructions, applicable codes & ordinances and

in a manner acceptable to the authority having jurisdiction.

**MARKING**: Listee's name, model number, electrical rating, and UL label.

APPROVAL: Listed as a fire alarm control unit for use with listee's separately listed electrically and

functionally compatible initiating and indicating devices. Refer to manufacturer's

Installation Manual for details.

These control units can generate a distinctive three-pulse Temporal Pattern Fire Alarm

Evacuation Signal (for total evacuation) in accordance with NFPA 72, 2002 Edition.

This control unit meets the requirements of UL-864, 9<sup>th</sup> Edition Standard.

NOTE: For Fire Alarm Verification Feature (delay of fire alarm signal), the maximum

Retard/Reset/Restart period shall not exceed 30 seconds.

\*Rev 06-02-2006 jw



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued: JULY 10, 2008 Listing Expires June 30, 2009

Authorized By: **BEN HO**, Chief

Fire Engineering Division